

Annual Drinking Water Quality Report **Greensboro, Maryland**

July 1, 2008

We're pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

The source of our drinking water is three wells drilled into the Piney Point aquifer, the Academy street well is 390 feet deep. The Hobbs street well is 350 feet deep and the Tower Road well is 370. An aquifer is an underground body of water, which is tapped by drilling wells and pumping the water to the surface for distribution. The 350 to 390 feet of earth between surface sources and this aquifer helps to purify the water before it actually reaches the aquifer, making it easier for us to treat before we pump it into your water distribution system.

We are pleased to report that our drinking water meets Federal and State requirements. The following report is provided in compliance with Federal regulations and will be provided annually. This report outlines the quality of our finished drinking water and what that quality means.

If you have any questions about this report or concerning your water utility, please contact the Town Manager, Mr. Dave Kibler at (410) 482-6222. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings held on the first and third Thursday of each month at Town Hall at 7:00 PM.

The Greensboro water department routinely monitors for contaminants in your drinking water according to Federal and State laws. The tables on the following pages show the results of our monitoring for the period of January 1st to December 31st, 2009. As water travels over the land or underground it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances.

Definitions

In this report you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (u/l) - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Non-Detected Contaminants

Greensboro is only required to provide information on those contaminants it has detected in the finished water supply.

Detected Contaminants Not in Violation of the MCL

Contaminant	Level	unit of Detected Measure- Ment	MCL	MCLG	Likely Source of Contamination
1. Copper	.044	mg/L	1.3	1.3	Corrosion of household plumbing; erosion of natural deposits
2. Lead	.003	mg/L	.015	0	Corrosion of household plumbing; erosion of natural deposits
3. DI (2-Ethylhexyl) Phthalate	1.3	ug/L	60	60	Discharge from rubber and chemical factories
4. Iron	.075	mg/L	0.3	0.3	Naturally present in the environment
5. Flouride	1.43	mg/L	4.0	4.0	Erosion of natural deposits; water additive
6. Arsenic	0.002	mg/l	.10	0	Erosion of natural deposits; runoff from orchards and production wastes
7. Gross Alfa	3.0	pCi/L	15	0	Erosion of natural deposits of certain minerals
8. Gross Beta	6.0	pCi/L	n/a	n/a	Decay of natural and manmade deposits of certain minerals
9. Nitaite	.002	mg/L	10	10	Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits
10. Chloriform	1.0	ppb	100	0	Disinfection by-products

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, **including bottled water**, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at (1-800-426-4791).

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Usted puede obtener informacion en espanol por llamar por telefono la casa del ayuntamiento de Greensboro, Maryland a (410) 482-6222.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care

providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791). Please call our office if you have questions.

The Town of Greensboro, Maryland is dedicated to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

The Town of Greensboro, Maryland
104 E. Sunset Avenue
P.O. Box 340
Greensboro, Maryland 21639
Phone (410) 482-6222
Fax (410) 482-7429